



- NOTES:**
1. CALL CEMC **BEFORE** BACKFILLING DITCH FOR CEMC DITCH INSPECTION
 2. CONDUIT SIZE FROM POLE TO TRANSFORMER TO BE 3". FROM TRANSFORMER TO METER BASE 3" UNLESS OTHERWISE NOTED BY CEMC SERVICE ENGINEER.
 3. CONDUIT SIZE FOR FIBER FROM POLE TO HOUSE TO BE 1".
 4. SEE DRAWING NO. 1P-F FOR CROSS-SECTION VIEW.

CEMC

UNDERGROUND PRIMARY/FIBER TO INDIVIDUAL CUSTOMERS

| | | |
|---------------|-------------|------------|
| Scale: N.T.S. | Drawing No. | |
| Drawn by: MB | P/F-1 | Sheet 1 of |
| Date: 8/19/19 | | 1 Sheets |